


# ENERGY AUDIT REPORT | 2022

# **ENERGY AUDIT REPORT 2022**

# CONSULTATION REPORT Adichunchanagiri University





#### **Submitted to:**

The Registrar, Adichunchanagiri University, Bengaluru – Hassan National Highway (NH-75), Nagamangala Taluk, BG Nagara – 571 448, Mandya District, Karnataka State, India



#### **Submitted by:**

Green Aura, 692F,12<sup>th</sup> A cross Bel layout, Bengaluru- 560091





# **CONTENT**

| Sr. No        | Item  |    |  |
|---------------|---|----|--|
| I             | Acknowledgement   | 3  |  |
| II            | Executive Summary   | 4  |  |
| Chapter-01    | Introduction  | 6  |  |
| 1.1           | About University  | 6  |  |
| 1.2           | About Energy Audit  | 11 |  |
| 1.3           | Methodology   | 12 |  |
| Chapter-02    | Power Supply System   | 13 |  |
| 2.1           | Transformer   | 13 |  |
| 2.2           | DG Sets   | 14 |  |
| 2.3           | UPS System  | 15 |  |
| 2.4           | Capacitor Bank  | 15 |  |
| 2.5           | Single line Diagram   | 16 |  |
| 2.6           | Solar System  | 17 |  |
| Chapter-03    | Energy Bill Analysis  | 18 |  |
| 3.1           | Energy Bill Analysis.   | 18 |  |
| 3.2           | Average Power Factor of the university                                | 19 |  |
| Chapter-04    | Connected Load System   | 20 |  |
| 4.1           | HVAC system   | 20 |  |
| 4.2           | Electrical Motors in University                                       | 20 |  |
| 4.3           | Lighting system of university   | 21 |  |
|               | Adichunchanagiri Hospital & Research centre                           |    |  |
| Chapter 2.2.1 | Transformers Adichunchanagiri Hospital & Research Centre              | 22 |  |
| 2.2.2         | DG Sets Adichunchanagiri Hospital & Research Centre                   | 23 |  |
| 2.2.3         | UPS System Adichunchanagiri Hospital & Research Centre                | 24 |  |
| 2.2.4         | Capacitor bank Adichunchanagiri Hospital & Research Centre            | 24 |  |
| 2.2.5         | Solar system Adichunchanagiri Hospital & Research Centre              | 25 |  |
| Chapter 3.2.1 | Electricity Bill Analysis Adichunchanagiri Hospital & Research Centre | 26 |  |
| 3.2.1         | Electricity Bill Analysis Adichunchanagiri Hospital & Research Centre | 26 |  |
| Chapter-4.2.1 | Connected Load System Adichunchanagiri Hospital & Research Centre     | 26 |  |
| Chapter-05    | Energy Conservation Measures  | 27 |  |
| Annexure 1    | Green Aura's ISO 17020, ISO9001                                       | 28 |  |
| Annexure 2    | Energy and Green Auditor Credentials                                  | 30 |  |





# **ACKNOWLEDGEMENT**

GREEN AURA, Bengaluru, Karnataka takes this opportunity to appreciate & thank the management of Adichunchanagiri University for giving us an opportunity to conduct Energy Audit for the University.

We are indeed touched by the helpful attitude and co-operation of all faculties and technical staff, who rendered their valuable assistance and co-operation the course of study.

#### **Energy Audit Team**

The study team constituted of the following senior technical executives from Green Aura:

- ♣ Mr. Nischay N Gowda, [Director, IGBC-AP, LEED-Green Associate]
- ♣ Mr. Rajesh Kumar Singadiya, [Accredited Energy Auditor, AEA-0284, Certified Energy Auditor CEA-7271 BEE, Ministry of Power, Govt. of India]
- **♣ Mr. Sachin Kumawat** [ Project Engineer]

Nischay N Gowda,

Nischall.

Director





# **EXECUTIVE SUMMARY**

The executive summary of the energy audit report furnished in this section briefly gives the identified energy conservation measures in the university.

#### AREAS FOR IMPROVEMENT

#### **POWER FACTOR IMPROVEMENT:**

- It was observing that the power factor of university is 0.88 of year-2022. It should maintain Unity by the capacitor health check-up on regular basis.
- It was observing that the power factor of university is 0.95 of year-2022. It should maintain Unity by the capacitor health check-up on regular basis.

#### **♣** DEMAND REDUCATION 1250 KVA TO 750 KVA.

It is analysed from last 01 Year electricity bills. Contract Demand of the Adichunchanagiri Hospital & Research centre is 1250 KVA. University has paid Rs. 22,91,640 extra charge on demand. So It is highly recommended to demand reduce 1250 KVA to 750 KVA. Total Expected Monitory saving is 12,48,000 per year.

#### **Details calculation in Chapter-05**

#### **LIGHTING SYSTEM:**

- Replacement of "conventional T-12 (40 Watt)" tube light by Energy Efficient LED lighting fixture T-5 (18Watt or 20 Watt) in all Buildings, have great potential for Energy saving. Expected Energy saving is the subject of load factor and total annual operating hours.
- ♣ Installation of "Timer control on Straight light and Focus light on Building" recommended for Energy saving in the campus.
- ♣ Installation of Motion sensor in Non-Working Area (Wash room, Electrical Room. etc.) recommended for Energy saving in the campus.
- ♣ Installation of "Solar Alone System" on Street lighting, campus Lighting and Building focus lighting are having good potential for energy saving as well as sustainable development and conservation of natural resources.





# Chapter-01 INTRODUCTION

#### 1.1 About University: -

The University is situated in a Lush Green Unitary Campus of 67 acres at B.G. Nagara, Nagamangala Tq., Mandya District, Karnataka on the Bangalore – Mangalore National Highway No. 75, 105 Kms from Bangalore, the Capital City of Karnataka.

The University consists of six Constituent colleges in the disciplines of Medicine, Pharmacy, Nursing, Engineering, Management, Commerce and Education. The environment-friendly campus has adequate infrastructure and physical facilities for Academics and Research. The campus possesses around 5000 students, 400 teachers and 1800 support staff.

The University employs a broad range of strategies to achieve its Vision, Mission and Objectives to expand the horizon of World Knowledge, provide instruction, Teaching-Learning, Training, Research and Development at the level of Higher Education in the faculties of Health Sciences, Engineering and Technology, Management and Technology

Following building bills and data are considered in this report Part-01

- **♣** BGS Institute of Technology
- **♣** BGS College of Education
- BGS first grade college.
- ♣ Adichunchanagiri School of Natural Science





#### **VISION**

Education for all with Value Systems of Empathy, Enrichment, Equity, Excellence, Empowerment, Entrepreneurship & Enlightenment to Serve the Society


#### **MISSION**

- Education to all for Self Reliance, Socio-Economic Change to develop an Inclusive Society with Shared Opportunities & Responsibilities
- Empathy towards the Less Fortunate, the Sick, the Suffering & the Disabled
- Enrichment to acquire Abundant Knowledge, Requisite Skills & Appropriate Attitude
- Excellence for Quality Assurance, Enhancement & Sustenance in Academics & Research to produce Graduates of Global Standards
- Equity for Fairness & Social Justice by providing Equal Opportunities
- Empowerment of Graduates to become Intuitive, Innovative & Inventive
- Entrepreneurship is a concept or idea involving the product or service to be delivered, or a new technology to be developed
- Enlightenment to attain Wisdom & Virtues in Life to think beyond Self
- Student Information System





#### Master Layout of the university: -







# Total area of the university

|        | AIMS College Block   |                 |               |                  |  |  |  |
|--------|----------------------|-----------------|---------------|------------------|--|--|--|
|        |                      | Old Exiting     | New building  | Total Building   |  |  |  |
| Sr. No | Building Name        | Building Up     | Build up Area | Build Up Area in |  |  |  |
|        |                      | Area (sqm)      | (sqm)         | (sqm)            |  |  |  |
| 1      | AIMS College         | 12,505.20       | 11801         | 24,306.20        |  |  |  |
| 2      | AIMS Library block   | 2750            | 4799          | 7,549            |  |  |  |
| 3      | Auditorium Block     | 2882.62         | 0             | 2,882.62         |  |  |  |
| 4      | AIIMS Forensic block | 1103            | 2151          | 3,254            |  |  |  |
| 5      | Animal house         | 372.67          | 0             | 372.67           |  |  |  |
| 6      | AIMS Teaching block  | 6569.66         | 0             | 6,569.66         |  |  |  |
|        | Total AIMS           | college Buildup | area          | 44,934.15        |  |  |  |

|        |                         | Hospital bl                              | ock                                    |   |
|--------|-------------------------|--|--|---|
| Sl. No | Building Name           | Old Exiting<br>Building Up<br>Area (sqm) | New building<br>Build up Area<br>(sqm) | Total Building<br>Build Up Area in<br>(sqm) |
| 1      | Hospita Block           | 3436.77                                  | 20343                                  | 57,779.77                                   |
| 2      | Ward Block              | 0  | 16820                                  | 16,820                                      |
| 3      | Casualty block          | 0  | 5792                                   | 5,792                                       |
| 4      | OBG BLOck               | 0  | 1400                                   | 1,400                                       |
| 5      | OT Block                | 0  | 3542                                   | 3,542                                       |
| 6      | ICU Block               | 0  | 1987                                   | 1,987                                       |
| 7      | OPD 2nd Floor           | 0  | 3018                                   | 3,018                                       |
| 8      | OPD 2nd Floor           | 0  | 1138                                   | 1,138                                       |
| 9      | Medical gas generator   | 0  | 374                                    | 380   |
| 10     | OT block to ward block  | 0  | 604                                    | 604   |
| 11     | ICU block to ward block | 0  | 806                                    | 307   |
|        | Total Bui               | ld up Area                               |  | 92,767.77                                   |





|        |                             | Residential 1                            | Block                                  |   |
|--------|-----------------------------|--|--|---|
| Sl. No | Building Name               | Old Exiting<br>Building Up<br>Area (sqm) | New building<br>Build up Area<br>(sqm) | Total Building<br>Build Up Area in<br>(sqm) |
| 1      | AIMS Boys hostel            | 5480.92                                  | 10981                                  | 16,461.92                                   |
| 2      | AIMS Girls hostel           | 12246.47                                 | 0                                      | 12,246.47                                   |
| 3      | K B Boys PG Hostel          | 4361.05                                  | 0                                      | 4,361.05                                    |
| 4      | K B Girls PG Hostel         | 3647.58                                  | 0                                      | 3,647.58                                    |
| 5      | AIMS Staff quarter          | 12601.76                                 | 0                                      | 12,601.76                                   |
| 6      | Nursing staff quarter       | 0  | 6977                                   | 6,977                                       |
| 7      | Principle quarter           | 1253.53                                  | 0                                      | 1,253.53                                    |
| 8      | Vijnatha bhawan             | 1894.28                                  | 0                                      | 1,894.28                                    |
| 9      | Manasa complex              | 2328.62                                  | 0                                      | 2,328.62                                    |
| 10     | Bank building               | 507.99                                   | 0                                      | 507.99                                      |
| 11     | Working women HO            | 3801.11                                  | 0                                      | 3,801.11                                    |
| 12     | Hospital canteen            | 351.3                                    | 0                                      | 351.3                                       |
|        | Total hospital buildup area |  |  | 66,432.61                                   |
|        | Tota                        | l area in sq mtr                         |  | 2,04,134.53                                 |





#### 1.2 About Energy Audit

Energy audit helps to understand more about the ways energy is used in any plant and helps in identifying areas where waste may occur and scope for improvement exists. The overall energy efficiency from generation to final consumer becomes 50%. Hence one unit saved in the end user is equivalent to two units generated in the power plant. (1 Unit / 0.5 Efficiency = 2Units)

Energy audit is the most efficient way to identify the strength and weakness of energy management practices and to find a way to solve problem. Energy audit is one kind of professional approach towards a responsible way in utilizing economic, financial, and social and natural resources. Energy audits can "add value" to the management approaches being taken by the institute and is a way of identifying, evaluating the system.

The GREEN AURA, Bengaluru, Karnataka carried out the energy audit at the site to find loopholes in the energy consumption pattern for Adichunchanagiri University. A technical report has been prepared as per the need and the requirement of the project.

#### 1.2 Objectives of Energy Auditing

The energy audit provides the vital information base for overall energy conservation program covering essentially energy utilization analysis and evaluation of energy conservation measures. It aims at:

- Identifying the quality and cost of various energy inputs.
- Assessing present pattern of energy consumption in different cost centers of operations.
- Relating energy inputs and production output.
- Identifying potential areas thermal and electrical energy economy.
- Highlighting wastages in major areas.
- Fixing of energy saving potential targets for individual cost centers.
- Implementation of measures for energy conservation & realization of savings.





#### 1.3 Methodology:

Methodology adopted for achieving the desired objectives viz.: Assessment of the current operational status and energy savings include the following:

- ♣ Discussions with the concerned officials for identification of major areas of focus and other related systems.
- → Team of engineers visited the site and had discussions with the concerned officials / supervisors to collected data / information on the operations and load distribution within the plant and same for the overall premises. The data was analyzed to arrive at a base line energy consumption pattern.
- ♣ Measurements and monitoring with the help of appropriate instruments including continuous and / or time-lapse recording, as appropriate and visual observations were made to identify the energy usage pattern and losses in the system.
- ♣ Trend analysis of costs and consumptions.
- ♣ Capacity and efficiency test of major utility equipment's, wherever applicable.
- **Lestimation** of various losses
- ♣ Computation and **in-depth analysis** of the collected data, including utilization of computerized analysis and other techniques as appropriate were done to draw inferences and to evolve suitable energy conservation plan/s for improvements/ reduction in specific energy consumption.





# Chapter – 02 Power Supply System

#### 2.1 Transformers

The power supply for the university is from Grid with the help of 11 KV feeders under Different Tariff Category. Sectioned load of the university is 200 KVA. University has a single transformer with Capacity 250 KVA



Figure: - 250 KVA Transformer photographs





#### 2.2 DG Sets: -

The university has 03 Nos DG sets to supply Emergency power during the grid Power Failure. The Capacity of the DG sets is given below.

| Sr. No | DG Location  | Capacity of DG | Quantity |
|--------|--------------|----------------|----------|
| 1      | Main College | 100            | 1        |
| 2      | Boys Hostel  | 100            | 1        |
| 3      | Girls Hostel | 62.5           | 1        |



Figure: - DG sets photographs in university

#### **Observation**

- **♣** DG set is used only in case of power failure.
- ♣ There is requirement of energy and fuel meters to monitor total unit generation with respect to fuel consumption





#### **2.3** :- **UPS** System

University has installed -09 Nos UPS system for Instrument, Lab and Other Equipment's during the power failure. Details are given in the table.

| Sr. No | Department | Capacity (KVA) | Quantity |
|--------|------------|----------------|----------|
| 1      | Office     | 20             | 1        |
| 2      | BOT Lab    | 30             | 2        |
| 3      | CSE        | 20             | 2        |
| 4      | CSE        | 10             | 2        |
| 5      | ISE        | 20             | 2        |
| 6      | ECE        | 20             | 2        |
| 7      | MECH       | 20             | 1        |
| 8      | CIVIL      | 5              | 1        |
| 9      | IS         | 60             | 2        |



Figure: - UPS System for Emergency Power failure


#### 2.4 Capacitor Bank

University has installed 120 kVAr capacitor bank to maintain Power factor to the feeder. Its Appreciable.





#### 2.5 Single Line Diagram of University







#### 2.6 Solar system: -

University has installed 200 KWp solar system for renewable energy in the campus.

Details of unit generation in given in table

| Sr. No | Month &<br>Year | Solar Unit<br>Generation (KWp) | No of<br>Days | Capacity Utilization<br>Factor (CUF) % |
|--------|-----------------|--------------------------------|---------------|--|
| 1      | Jan-22          | 25,980                         | 31            | 17.5                                   |
| 2      | Feb-22          | 25,380                         | 28            | 18.9                                   |
| 3      | Mar-22          | 25,440                         | 31            | 17.1                                   |
| 4      | Apr-22          | 24,540                         | 30            | 17.0                                   |
| 5      | May-22          | 10,366                         | 31            | 7.0                                    |
| 6      | Jun-22          | 20,880                         | 30            | 14.5                                   |
| 7      | Jul-22          | 17,880                         | 31            | 12.0                                   |
| 8      | Aug-22          | 19,680                         | 31            | 13.2                                   |
| 9      | Sep-22          | 20,700                         | 30            | 14.4                                   |
| 10     | Oct-22          | 21,660                         | 31            | 14.6                                   |
| 11     | Nov-22          | 20,514                         | 30            | 14.2                                   |
| 12     | Dec-22          | 21,765                         | 31            | 14.6                                   |
|        | Total           | 2,54,785                       | 365           | 14.6                                   |




Figure: - Capacity Utilization factor of Solar System Year 2022

#### **Observation: -**

Total unit generation of Jan-2022 to Dec-2022 is 2,54,785 units. And average capacity utilization factor is 14.6 %. Which is lower It is recommended to cleaning of solar panel frequently to increase CUF.





### Chapter-03 Energy Bill analysis

#### 3.1 Electricity Bill Analysis:-

Energy audit team was analysed Electricity bills of last one year. Details of unit consumption, annual average power factor and annual per unit charges are determined as follow:

| Sr. No | Month & Year | Unit<br>Consumption<br>(KVA) | Unit<br>Consumption<br>(kWh) | Power<br>Factor | Billing<br>Amount<br>(Rs) | Overall per unit<br>Charges (Rs/ kVAh) |
|--------|--------------|------------------------------|------------------------------|-----------------|---------------------------|--|
| 1      | Jan-22       | 50,430                       | 44,380                       | 0.88            | 3,64,536                  | 7.2                                    |
| 2      | Feb-22       | 45,990                       | 38,340                       | 0.83            | 3,43,441                  | 7.5                                    |
| 3      | Mar-22       | 61,150                       | 57,390                       | 0.94            | 4,54,660                  | 7.4                                    |
| 4      | Apr-22       | 59,440                       | 50,940                       | 0.86            | 4,48,142                  | 7.5                                    |
| 5      | May-22       | 57,280                       | 50,900                       | 0.89            | 4,02,897                  | 7.0                                    |
| 6      | Jun-22       | 55,570                       | 49,780                       | 0.90            | 4,44,251                  | 8.0                                    |
| 7      | Jul-22       | 56,156                       | 50,526                       | 0.90            | 4,50,779                  | 8.0                                    |
| 8      | Aug-22       | 54,310                       | 48,330                       | 0.89            | 4,33,564                  | 8.0                                    |
| 9      | Sep-22       | 56,130                       | 49,970                       | 0.89            | 4,63,898                  | 8.3                                    |
| 10     | Oct-22       | 46,460                       | 38,740                       | 0.83            | 3,71,233                  | 8.0                                    |
| 11     | Nov-22       | 52,030                       | 45,220                       | 0.87            | 4,24,271                  | 8.2                                    |
| 12     | Dec-22       | 47,625                       | 42,253                       | 0.89            | 3,81,000                  | 8.0                                    |
|        | Total        | 6,42,571                     | 5,66,769                     | 0.88            | 49,82,672                 | 7.8                                    |




Figure:- Graphical Presentation of Overall per unit charges year-2022

#### **Observation:**

It was found that total energy consumption in the last 12 months was 6,42,571 units. The average annual energy charges is Rs 7.8 /kVAh.





#### 3.2: - Average Power Factor of the university

| Sr. No | Month & Year | Power<br>Factor |
|--------|--------------|-----------------|
| 1      | Jan-22       | 0.88            |
| 2      | Feb-22       | 0.83            |
| 3      | Mar-22       | 0.94            |
| 4      | Apr-22       | 0.86            |
| 5      | May-22       | 0.89            |
| 6      | Jun-22       | 0.90            |
| 7      | Jul-22       | 0.90            |
| 8      | Aug-22       | 0.89            |
| 9      | Sep-22       | 0.89            |
| 10     | Oct-22       | 0.83            |
| 11     | Nov-22       | 0.87            |
| 12     | Dec-22       | 0.89            |
|        | Average      | 0.88            |




Figure: - Graphical presentation of average power factor of the university Year-2022

#### **Observation:**

♣ The average power factor was 0.88 for the year 2022. It is the recommended to maintain power factor unity.





# Chapter-04 Connected Load System

#### 4.1 HVAC system

University has installed Package chillier, Split AC, Window AC for cooling system in university. Details are given in below.

| Sr. No | Types of Equipment's    | Quantity | Capacity | Unit |
|--------|-------------------------|----------|----------|------|
| 1      | Chillers/ Window /Split | 56       | 346      | TR   |
| 2      | Split AC                | 47       | 70.5     | TR   |
| 3      | Exhaust Blower          | 2        | 20       | kW   |

#### 4.2 Electrical Motors in University.

University has installed various type of motor for different application. Details are given in the table.

| Sr<br>. No | Department               | Capacity<br>(HP) | Capacity<br>(KW) | Quantity (Nos) | Total<br>kW |
|------------|--------------------------|------------------|------------------|----------------|-------------|
| 1          |                          | 1                | 0.746            | 15             | 11.19       |
| 2          | 36 1 1 1                 | 10               | 7.46             | 1              | 7.46        |
| 3          | Mechanical<br>Department | 5                | 3.73             | 1              | 3.73        |
| 4          | -                        | 1                | 0.746            | 9              | 6.714       |
| 5          |                          | 0.5              | 0.373            | 1              | 0.373       |
| 6          |                          | 5                | 3.73             | 1              | 3.73        |
| 7          | Water Supply             | 3                | 2.238            | 3              | 6.714       |
| 8          |                          | 2                | 1.492            | 2              | 2.984       |
| 9          |                          | 3                | 2.238            | 4              | 8.952       |
| 10         | Boys Hostel              | 2                | 1.492            | 3              | 4.476       |
| 11         |                          | 1                | 0.746            | 3              | 2.238       |
| 12         | Heat Pump                | 6                | 4.476            | 2              | 8.952       |
| 13         | Fire Hydrant             | 5                | 3.73             | 1              | 3.73        |
| 14         | Garden Water Pump        | 5                | 3.73             | 1              | 3.73        |
|            | Total KW in Motors       |                  |                  | 47             | 74.973      |





# 4.3 Lighting system of university: -

University has installed different types of lighting system. Details are given in the table

| Sr. No | Location   | Rated Power (Watt) | Quantity | Total Power (kW) |
|--------|------------|--------------------|----------|------------------|
| 1      | Tube light | 40                 | 416      | 16.64            |
| 2      | LED Light  | 20                 | 9        | 0.18             |
| 3      | LED Light  | 18                 | 40       | 0.72             |
| 4      | LED Light  | 9                  | 11       | 0.099            |
|        | Т          | 17.639             |          |                  |





### PART-02: - Adichunchanagiri Hospital & Research centre

Following building bills and data are considered in this part-02

- ♣ Adichunchanagiri Institute of medical Science
- ♣ Adichunchanagiri College Medical Science
- ♣ Adichunchanagiri College Nursing
- ♣ Adichunchanagiri College of Pharmacy

# Chapter 2.2.1 Power Supply System

#### 2.2.1 Transformers Adichunchanagiri Hospital & Research Centre

The power supply for the Adichunchanagiri Hospital & Research Centre is from grid, with the help of 11 KV feeders under Different Tariff Category. Sectioned load of the university is 1250 kVA. University has 04 Nos transformer for Adichunchanagiri Hospital & Research Centre 02 Transformer is 1000 KVA and two other is 500 KVA.



Figure: - 1000 KVA Transformer Photographs





#### 2.2.2 DG Sets Transformers Adichunchanagiri Hospital & Research Centre

The university has 04 Nos DG sets to supply Emergency power during the grid Power Failure. The Capacity of the DG sets is given below.

| Sr. No | Capacity of DG | Quantity |
|--------|----------------|----------|
| 1      | 750            | 1        |
| 2      | 500            | 2        |
| 3      | 200            | 1        |



#### **Observation**

- **♣** DG set is used only in case of power failure.
- ♣ There is requirement of energy and fuel meters to monitor total unit generation with respect to fuel consumption





#### 2.2.3: - UPS System

University has installed 750 KVA UPS system for Instrument, Lab and Other Equipment's during the power failure for emergency power supply. **Its appreciable** 



Figure: - UPS System for Emergency Power failure

#### 2.2.4 Capacitor Bank

University has installed three no's of capacitor bank to maintain Power factor to the feeder. Its Appreciable. Details are given in below.

- 4 350 kVAr = 02
- **♣** 250 kVAr =01





#### 2.2.5 Solar system Adichunchanagiri Hospital & Research Centre

University has installed solar system for renewable energy in the campus.

Details of unit generation in given in table

| Sr<br>.no | Month &<br>Year | Solar Energy<br>Generated (KWH) |
|-----------|-----------------|---------------------------------|
| 1         | Jan-22          | 29,760                          |
| 2         | Feb-22          | 30,562                          |
| 3         | Mar-22          | 29,256                          |
| 4         | Apr-22          | 29,653                          |
| 5         | May-22          | 26,636                          |
| 6         | Jun-22          | 27,017                          |
| 7         | Jul-22          | 28,437                          |
| 8         | Aug-22          | 28,569                          |
| 9         | Sep-22          | 27,337                          |
| 10        | Oct-22          | 29,046                          |
| 11        | Nov-22          | 29,900                          |
| 12        | Dec-22          | 27,000                          |
|           | Total           | 3,43,173                        |




Figure: - Capacity Utilization factor of Solar system Year 2022

#### **Observation: -**

Total unit generation of Year-2022 is 3,43,173 units.





#### Chapter-03 Energy Bill analysis

#### 3.3.1 Electricity Bill Analysis Adichunchanagiri Hospital & Research:-

Energy audit team was analysed Electricity bills of last one year. Details of unit consumption, annual average power factor and annual per unit charges are determined as follow:

| Sr.no | Month  | Energy Consumption |  |  |
|-------|--------|--------------------|--|--|
| Sr.no | & Year | (kWh)              |  |  |
| 1     | Jan-22 | 1,64,625           |  |  |
| 2     | Feb-22 | 1,66,800           |  |  |
| 3     | Mar-22 | 2,27,250           |  |  |
| 4     | Apr-22 | 2,58,825           |  |  |
| 5     | May-22 | 2,58,225           |  |  |
| 6     | Jun-22 | 2,31,925           |  |  |
| 7     | Jul-22 | 2,26,950           |  |  |
| 8     | Aug-22 | 2,17,650           |  |  |
| 9     | Sep-22 | 2,18,625           |  |  |
| 10    | Oct-22 | 2,03,475           |  |  |
| 11    | Nov-22 | 1,83,900           |  |  |
| 12    | Dec-22 | 1,91,250           |  |  |
|       | Total  | 25,49,500          |  |  |




Figure :- Graphical Presentation of Overall per unit charges year-2021-22

#### **Observation:**

It was found that total energy consumption in the last 12 months was 25,49,500 units





# Chapter-04 Connected Load System

# 4.2.1 HVAC system

University has installed following HVAC equipment's system for Hospital and research centre. Details are given in table.

| Sr. No | Types of Equipment's  | Quantity | Capacity | Unit |
|--------|-----------------------|----------|----------|------|
| 1      | AHU                   | 17       | 285.6    | HP   |
| 2      | FCUs Unit             | 47       | 800      | HP   |
| 3      | Packaged Acs          | 2        | 26.4     | HP   |
| 4      | Split Ac              | 50       | 120      | HP   |
| 5      | Exhaust Blower        | 55       | 275      | HP   |
| 6      | Fresh Air Blower      | 10       | 50       | HP   |
| 7      | Bore well             | 6        | 30       | HP   |
|        | Total HVAC Load in HP | 1597     |          |      |





# **Chapter-05 Energy Conservation Measures**

#### Case Study-01

Demand Reduction of the Adichunchanagiri Hospital & Research centre

**Observation:** - It is analysed from last 01 Year electricity bills. Contract Demand of the Adichunchanagiri Hospital & Research centre is 1250 KVA. University has paid Rs. 22,91,640 extra charge on demand.

Minimum Recorded demand in Jan-2022 = 375 KVA.

Maximum Recorded demand in May-2022 = 701 KVA

Average Recorded Demand (Oct-2021 to Sep-2022) = 519 KVA.

| Sr.No. | Month &<br>Year | Contract Demand (KVA)                   | Maximum<br>Demand (KVA) | Unused<br>Demand<br>(KVA) | Extra Amount pay on demand (RSs) |
|--------|-----------------|---|-------------------------|---------------------------|----------------------------------|
| 1      | Oct-21          | 1250                                    | 425                     | 825                       | 2,14,500/-                       |
| 2      | Nov-21          | 1250                                    | 425                     | 825                       | 2,14,500/-                       |
| 3      | Dec-21          | 1250                                    | 394                     | 856                       | 2,22,560/-                       |
| 4      | Jan-22          | 1250                                    | 375                     | 875                       | 2,27,500/-                       |
| 5      | Feb-22          | 1250                                    | 405                     | 845                       | 2,19,700/-                       |
| 6      | Mar-22          | 1250                                    | 554                     | 696                       | 1,80,960/-                       |
| 7      | Apr-22          | 1250                                    | 680                     | 570                       | 1,48,200/-                       |
| 8      | May-22          | 1250                                    | 701                     | 549                       | 1,42,740/-                       |
| 9      | Jun-22          | 1250                                    | 594                     | 656                       | 1,70,560/-                       |
| 10     | Jul-22          | 1250                                    | 564                     | 686                       | 1,78,360/-                       |
| 11     | Aug-22          | 1250                                    | 539                     | 711                       | 1,84,860/-                       |
| 12     | Sep-22          | 1250                                    | 530                     | 720                       | 1,87,200/-                       |
|        |                 | Total Extra Amount pay on Demand Charge |                         |                           | 22,91,640/-                      |

**Recommendation: -**

There is good potential to demand reduced 1250 KVA to 750 KVA. Details calculation in below

1250 KVA- 750 KVA = 400 KVA.

Saving Calculation: -

400 KVA X 260 X 12 = Rs 12,48,000.

(Rs 260 per KVA Demand Charge)

**Total Investment: - NIL** 






#### Annex 1 ISO17020:2012







Annex 2 ISO9001:2015







# Annex 3 Green and Energy certification



# **BUREAU OF ENERGY EFFICIENCY**

Examination Registration No.: EA-7271

Accreditation Registration No.: AEA-284



# Certificate of Accreditation

The certificate is subject to the provisions of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

This certificate shall be valid until it is cancelled under regulation 9 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

On cancellation, the certificate of accreditation shall be surrendered to the Bureau within fifteen days from the date of receipt of order of cancellation.

Your name has been entered at AEA No....284.... in the register of list of accredited energy auditors. Your name shall be liable to be struck out on the grounds specified in regulation 8 of the Bureau of Energy Efficiency (Qualifications for Accredited Energy Auditors and Maintenance of their List) Regulations, 2010.

Given under the seal of the Bureau of Energy Efficiency, Ministry of Power, this 5° day of October, 2018

Secretary, Bureau of Energy Efficiency New Delhi





GREEN BUSINESS CERTIFICATION INC. CERTIFIES THAT

# Nischay N

HAS ATTAINED THE DESIGNATION OF

# LEED<sup>®</sup> Green Associate™

by demonstrating the knowledge and understanding of green building practices and principles needed to support the use of the LEED green building program.

Malesh Rananyan

MANESH RAMANUJAN

PRESIDENT & CEO, U.E. GREEN BULLETING COUNCIL

PRESIDENT & CEO, GREEN BUSINESS CENTIFICATION INC.





