



SAST/CLPC/ACU-AH & RC/ **86** /2025-26

25.08.2025

TENDER NOTIFICATION

The Head, CLPC, Sri Adichunchanagiri Shikshana Trust invites closed tenders from eligible tenderers or Bonafide licensed manufacturer (OEM) or their authorized local supplier/ dealer/ distributor in the state of Karnataka for the New construction. Procurement of Fire Fighting System works at AH&RC, ACU, BG Nagara as per section I & II.

01	Name of the work	Procurement of Fire Fighting System works at AH&RC
02	Last Date for Tender Submission	On or before 28.08.2025, 5:30 PM

Section-1

Instructions to Tenderers

- 1) The Tenderer shall submit the bids (Technical & Financial bids) through the mail id: **clpchead@bgscet.ac.in** on or before the last date of tender submission (for any or all list of items) on professional business letterheads only. The details to be printed on the letter head is as follows
 - i) Tender for Procurement of Fire Fighting System works at AH&RC, ACU BG Nagara.
 - ii) Tender Reference number **AHRC/ACU/U-204/2025-26** Dated **19.08.2025**
 - iii) Address to "The HEAD, CLPC, Sri Adichunchanagiri Shikshana Trust, BGSCET Campus, Mahalakshmiapuram, Bengaluru - 560086"
 - iv) The tenderer shall submit the original documents to this office on the last day of submission for verification who prefers to submit the tender through Post can dispatch the same through Registered post / Speed post or Couriers as to reach the above address on or before the due date and time specified in the Tender Notice. Tenders received after the due date and time, for what so ever reasons will not be considered and the authority, Head of CLPC will not be liable or responsible for the same.
- 2) **Tender Currency:** Prices shall be quoted in Indian Rupees only.
- 3) **AMC/CMC (IF ANY)** is subject to the Sri Adichunchanagiri shikshana trust's norms.
- 4) **Warranty:** 3 Years
- 5) **Amendment of tender documents:** At any time prior to the deadline of submission of tenders the trust may, for no reason, whether as its own initiative or otherwise modify the tender documents by amendment. Sri Adichunchanagiri Shikshana Trust reserves all the rights to accept, reject, incorporate changes and re-tender without giving any reasons.
- 6) **Documents Comprising the Tender:** Shall attach Brochure, Certification of the product, Bank/account details, PAN, GSTIN, Good Standing Certificate and 02

1 | Page
**THE HEAD
CLPC, ACU**



years of ITR declaration inside the envelope and the company contact details with email id on the in the below mention format in annexure -

- 7) **Tender Prices:** Prices indicated on the price schedule shall be entered separately I.e. the price of the goods, quoted (ex-works, ex-factory, ex-showroom, ex-warehouse, or off-the-shelf, as applicable), including all duties and sales and the other taxes already paid or payable. Any Indian duties, sales and other taxes which will be payable on the goods if the contract is awarded. Conditional tenders will not be considered. The bidder has to give the quotation in the below enclosed format in annexure - 2.
- 8) **Validity of the Bid:** 90 days from the last date of submission of bid.
- 9) **Corrupt or Fraudulent practices:** Sri Adichunchanagiri Shikshana Trust requires that the tenderers, observe the highest standard of ethics during the procurement and execution of such contracts. In purchase of this policy:
 - a) Will reject a proposal for award if it determines the tenderer recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question;
 - b) Will declare a firm ineligible, either indefinitely or for the stated period of time, to be awarded a university contract if it any time determines that the firm has engaged in corrupt or fraudulent practices in competing for, or in executing, a trust contract.
- 10) **Process to be confidential:** Information relating to the examination, clarification, evaluation, and comparison of tenders and recommendations for the award of contract will not be disclosed to tenderers or any other persons not officially concerned with such process until the award to the successful tenderer has been announced. Any effort by a tenderer to influence the employer's processing of tenders or award decisions may result in rejection of his tender.
- 11) **Clarification of Tenders:** To assist in the examination, evaluation, and comparison of tenders the employer may, at his discretion, ask and tenderer for clarification of his tender, including breakdowns of unit rates. The request for clarification and the response shall be writing or by cable, but no change in the price or substance of the tender shall be sought, offered, or permitted except as required to confirm the correction of arithmetic errors discovered by the employers in the evaluation of the tenders.
- 12) **Delivery:** The successful BIDDER should commence the service as per the tender document/work or purchase order. For any queries or assistance, please write to clpchead@bgscet.ac.in or telephone to +91-8123707324.
- 13) **Penalty Clause:** Non-execution of supply order – for the reasons of failure to supply partially or completely within the stipulated time or any event of breach of contract. In case at any following stages
 - a) For the delayed supply (3 days of grace period) – 5% deduction
 - b) Quantity issues – 5 % deduction
 - c) Quality issues – 10% deduction



Section-2

BOQ			
SL. NO	DESCRIPTION	UNIT	QTY
A	FIRE PUMP ROOM EQUIPMENT		
1.0	Supplying, Installing, Testing & Commissioning of Electrical Motor Driven Main Pump of horizontal centrifugal end suction backpull out type with gland packing and capable to deliver 2280 lpm at 70 MWC. Pump shall be coupled to suitable HP and suitable RPM Motor, complete set shall mounted on common base frame and foundation bolts, supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2
2.0	Supplying, Installing, Testing & Commissioning of Diesel Engine Driven Pump , horizontal centrifugal end suction backpull out type with gland packing and capable to deliver 2280 lpm at 70 MWC, Pump shall coupled to suitable HP of Diesel engine water cooled type with speed of suitable RPM and complete set shall be mounted on common base frame. Quoted rate shall includes Batteries, Battery Leads, Battery Stand, Fuel Tank (Diesel will be supplied by Client) for 6 Hrs. operation with MS Fabricated Stand, Gauge Glass, Valves & required Piping, Radiator, Coupling Gaurd, Foundation Bolts, Supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2
3.0	Supplying, Installing, Testing & Commissioning of Electrical Motor Driven Jockey Pump of horizontal centrifugal end suction back pull out type with gland packing and capable to deliver 180 lpm at 70 MWC, Pump shall be coupled to suitable HP and suitable RPM Motor, complete set shall mounted on common base frame and foundation bolts, supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2
4.0	Supplying, Installing, Testing & Commissioning of MCC Panel , to make Electrical Motor Driven Main Pump, Diesel Engine Driven Pump and Electrical Motor Driven Jockey Pump operate in Auto Mode, at set pressure, Panel shall be mounted on common base frame with foundation bolts, supports and all other required accessories, complete. Incoming power supply for MCC Panel shall be provided by Client, in side Fire Pump Room. (Civil Work : Client Scope) (Approved Make: Rihan powers)	Nos.	1
5.0	Supplying, Laying, Testing & Commissioning of FRLS, PVC outer sheath, steel armoured, Aluminium / Copper conductor, 1100V grade Power Cables with glands etc, cost shell include cable laying charges		
a	2C x 1.5 sq.mm Steel Armoured Copper Cable	Rmt.	72
b	4C x 16sqmm Steel Armoured Aluminuim Cable	Rmt.	24
c	3.5C x 70 sqmm Steel Armoured Aluminuim Cable	Rmt.	48
e	12C x 2.5 sqmm Steel Armoured Aluminuim Cable	Rmt.	24



6.0	Supplying, Installing, Testing & Commissioning of Perforated G.I. Cable Tray with necessary angle iron suspension supports, anchor fasteners etc. complete. Maximum height of suspension shall not exceed 500 mm. Size of the Cable Tray shall be suitable for laying the above mentioned cables.		
a	50mm width x 40mm height	Rmt.	Ro
b	75mm width x 40mm height	Rmt.	6
c	100mm width x 40mm height	Rmt.	12
d	200mm width x 40mm height	Rmt.	Ro
e	300mm width x 40mm height	Rmt.	18
7.0	Supplying, Installing, Testing & Commissioning of G.I. Earthing Strips , it shall be run on floor / ceiling / walls, from MCC Panel to all Pumps with necessary accessories as required. Earthing for MCC Panel should be provided by Client.		
a	50mm x 6mm	Rmt.	50
b	25mm x 3mm	Rmt.	50
8.0	Supplying, Installing, Testing & Commissioning of MS "C" Class Pipes , Heavy grade, Cutting & Fixing the Pipe on Walls / Hanging from ceiling complete. Pipe Fittings such as Reducers, elbows will be Butt Welded Fittings for all size pipes, it should include MS Support such as "L" Angle, as per drawing and all other GI support like Fastener, Thread Rod, U Clamps, U Bolt, Nut, Bolt & Washer, etc., Quoted Rate includes 1 coat of primer and 2 coats of Paint for the Entire System		
a	200mm nominal dia	Rmt.	40
b	250mm nominal dia	Rmt.	30
9.0	Supplying, Installing, Testing & Commissioning of GI "C" Class Pipes confirming to IS 1239 Pt - I Heavy grade, Cutting & Fixing the Pipe on Walls / Hanging from ceiling complete. Pipe Fittings such as Reducers, elbows will be Butt Welded Fittings for all size pipes, it should include MS Support such as "L" Angle, as per drawing and all other GI support like Fastener, Thread Rod, U Clamps, U Bolt, Nut, Bolt & Washer, etc., Quoted Rate includes 1 coat of primer and 2 coats of Paint for the Entire System		
a	50mm nominal dia	Rmt.	Ro
b	80mm nominal dia	Rmt.	25
c	100mm nominal dia	Rmt.	1350
d	150mm nominal dia	Rmt.	1250
10.0	Supplying, Installing, Testing & Commissioning of C.I. Non Return Valves (PN 16) as per IS:5312 wafer type with required flanges, nuts, bolts and gaskets etc. complete.		
a	80 mm nominal dia	Nos.	2
b	150 mm nominal dia	Nos.	4



11.0	Supplying, Installing, Testing & Commissioning of C.I. Butterfly Valves as per BS 5155 (PN 16) slim seal standard lever operated type with required flanges, nuts, bolts etc.		
a	50mm nominal dia	Nos.	Ro
b	80mm nominal dia	Nos.	2
c	100mm nominal dia	Nos.	2
d	150mm nominal dia	Nos.	4
e	200mm nominal dia	Nos.	5
f	250 mm nominal dia (Gear Operated Type)	Nos.	1
12.00	Supplying, installing and commissioning C. I. flanged "Y" type Strainer with SS mesh, suitable flanges, nuts, bolts, gaskets etc. complete. (suction side) (PN10)		
a)	250mm dia.	Nos.	1
13.0	Supplying, Installing, Testing & Commissioning of C.I. Sluice Valves (PN 16) with required flanges, nuts, bolts etc.		
a	80mm nominal dia	Nos.	2
b	100mm nominal dia	Nos.	Ro
c	150mm nominal dia	Nos.	4
14.0	Supplying, Installing, Testing & Commissioning of suitable range Pressure Gauge for pumpsets with 15mm Needle Valve , fittings like unions / colors / reducers etc.	Nos.	2
15.0	Supplying, Installing, Testing & Commissioning of Pressure Switch suitable range for pumpsets with 15mm Needle Valve , fittings like unions / colors / reducers etc.	Nos.	6
16.0	Supplying, Installing, Testing & Commissioning of Automatic Air Release Valve with 20mm Needle Valve , fittings like unions / colors / reducers etc.		
a	20 mm nominal dia	Nos.	2
17.0	Supplying, Installing, Testing & Commissioning of Gun metal chrome finished Needle Valves with fittings of screwed end type.		
a	15mm nominal dia	Nos.	22
b	20 mm nominal dia	Nos.	12
18.0	Supplying, Installing, Testing & Commissioning of Gun metal chrome finished Needle Valves with fittings of screwed end type.		
a	25mm nominal dia	Nos.	4



19.0	Supplying, Installing, Testing & Commissioning of Exhaust Pipe for Diesel Engine, 150 mm dia M.S. Heavy grade Pipe with mineral wool insulation with aluminum sheeting.	Rmt.	50
20.0	Supplying, Installing, Testing & Commissioning 100mm & 150mm dia M.S. Heavy Grade Pipe , shall be laid above ground with structural steel supports.	Rmt.	300
21.0	Excavation of trenches up to 1.5 mts. in depth, for laying pipes upto 150mm dia. Including forming bottom surface to required level, refilling the trenches with selected excavated earth around the pipe in layers of 150mm thick, watering, consolidating. Quoted price inclusive of disposing off / Carting away the surplus earth out side the site to a dump yard acceptable local bodies or as directed by the site engineer with a lead of 300 mts. etc. complete.	Cum	200
22.0	Supplying, installing, testing and commissioning of yard hydrant comprising of the following,		
a)	Single headed hydrant valve as per IS 5290, made of Stainless Steel (SS316) with 63 mm dia instantaneous outlet of 80 mm dia flanged inlet, Blank caps, chain and hand wheels etc. complete.	Nos.	12
b)	2 lengths of 15 M long, 63mm dia RRL hose with instantaneous couplings and Hoses shall be stored in side the hose cabinet.	Nos.	12
c)	1 no. Stainless Steel (SS316) short branch pipe with nozzle.	Nos.	12
d)	M.S. Hose cabinet stand mounted type fabricated out of M.S. sheet of 16 swg. with glass fronted (4mm thick glass with rubber beeding) door and size of the cabinet shall be 600mm x 750 mm x 250 mm Quoted rate shall be includes suitable stand for mounting, all fasteners etc., and cabinet shall be powder coated of approved colour both inside and out side.	Nos.	12
B HYDRANT AND SPRINKLER SYSTEM			
1.0	Supplying, Installing, Testing & Commissioning of 2 way Fire Brigade Inlet connection with built-in 2nos 63 mm dia. SS Non- Return Valves, instantaneous coupling type.	Nos.	1
2.0	Supplying, Installing, Testing & Commissioning of 4 way Fire brigade inlet connection with built-in 4 no. 63 mm dia. SS Non- Return Valves, instantaneous coupling type.	Nos.	1
3.0	Supplying, Installing, Testing & Commissioning of C.I. Butterfly Valves as per BS 5155 (PN 16) slim seal standard lever operated type with required flanges, nuts, bolts etc.		
a	100mm nominal dia	Nos.	12
b	150mm nominal dia	Nos.	12



4.0	Supplying, Installing, Testing & Commissioning of GI "C" Class Pipes confirming to IS 1239 Pt - I Heavy grade pipe, laying all size pipes below ground with Butt Welded Fittings like Reducers & elbows, Wrapping & Coating for all Pipes with 4mm thick Polymer Corrosion Resistant Tape with a overlap of 15mm. Quoted Rate includes Excalvation up to 1 mts depth in regular soil / soft rock / hard rock and refilling the same with M Sand and compacting it to original condition and removing the extra soil from site.		
a	80mm nominal dia	Rmt.	Ro
b	100mm nominal dia	Rmt.	Ro
c	150mm nominal dia	Rmt.	1950
5.0	supplying,fabricated and installing of M.S fabricating supports pipies and building to building supports	KG	2400
6.0	scfolding charges for vertical piping support	LOT	1
SUMMARY OF FIRE FIGHTING WORKS			
TOTAL OF PART - B			

[Signature]



Annexure – 1

PARTICULARS OF THE BIDDER

Sr. No	Description	Details (to be filled by the responder to the Bid)
1	Name of the company	
2	Official address	
3	Phone No. And Fax No.	
4	Corporate Headquarters Address	
5	Phone No. And Fax No.	
6	Web Site Address	
7	Details of Company's Registration (Please enclose copy of the company registration document)	
8	Name of Registration Authority	
9	Registration Number and Year of Registration	
10	ISO certifications and its validity	
11	GST registration No.	
12	Permanent Account Number (PAN)	
13	Company's Revenue for last 3 years (Year wise)	
14	Company's net worth for the last year	
15	Bank Details (Name, Account no., Branch, IFSC, MICR)	



Annexure – 2

BOQ					
SL. NO	DESCRIPTION	UNIT	QTY	RATE	AMOUNT
A	FIRE PUMP ROOM EQUIPMENT				
1.0	Supplying, Installing, Testing & Commissioning of Electrical Motor Driven Main Pump of horizontal centrifugal end suction backpull out type with gland packing and capable to deliver 2280 lpm at 70 MWC. Pump shall be coupled to suitable HP and suitable RPM Motor, complete set shall mounted on common base frame and foundation bolts, supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2		-
2.0	Supplying, Installing, Testing & Commissioning of Diesel Engine Driven Pump , horizontal centrifugal end suction backpull out type with gland packing and capable to deliver 2280 lpm at 70 MWC, Pump shall coupled to suitable HP of Diesel engine water cooled type with speed of suitable RPM and complete set shall be mounted on common base frame. Quoted rate shall includes Batteries, Battery Leads, Battery Stand, Fuel Tank (Diesel will be supplied by Client) for 6 Hrs. operation with MS Fabricated Stand, Gauge Glass, Valves & required Piping, Radiator, Coupling Gaurd, Foundation Bolts, Supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2		-
3.0	Supplying, Installing, Testing & Commissioning of Electrical Motor Driven Jockey Pump of horizontal centrifugal end suction back pull out type with gland packing and capable to deliver 180 lpm at 70 MWC, Pump shall be coupled to suitable HP and suitable RPM Motor, complete set shall mounted on common base frame and foundation bolts, supports and all other required accessories, complete. (Civil Work : Client Scope)	Nos.	2		-

Handwritten signature



4.0	Supplying, Installing, Testing & Commissioning of MCC Panel , to make Electrical Motor Driven Main Pump, Diesel Engine Driven Pump and Electrical Motor Driven Jockey Pump operate in Auto Mode, at set pressure, Panel shall be mounted on common base frame with foundation bolts, supports and all other required accessories, complete. Incoming power supply for MCC Panel shall be provided by Client, in side Fire Pump Room. (Civil Work : Client Scope) (Approved Make: Rihan Powers)	Nos.	1		-
5.0	Supplying, Laying, Testing & Commissioning of FRLS, PVC outer sheath, steel armoured, Aluminium / Copper conductor, 1100V grade Power Cables with glands etc, cost shall include cable laying charges				
a	2C x 1.5 sq.mm Steel Armoured Copper Cable	Rmt.	72		-
b	4C x 16sqmm Steel Armoured Aluminum Cable	Rmt.	24		-
c	3.5C x 70 sqmm Steel Armoured Aluminum Cable	Rmt.	48		-
e	12C x 2.5 sqmm Steel Armoured Aluminum Cable	Rmt.	24		-
6.0	Supplying, Installing, Testing & Commissioning of Perforated G.I. Cable Tray with necessary angle iron suspension supports, anchor fasteners etc. complete. Maximum height of suspension shall not exceed 500 mm. Size of the Cable Tray shall be suitable for laying the above mentioned cables.				
a	50mm width x 40mm height	Rmt.	Ro		
b	75mm width x 40mm height	Rmt.	6		-
c	100mm width x 40mm height	Rmt.	12		-
d	200mm width x 40mm height	Rmt.	Ro		
e	300mm width x 40mm height	Rmt.	18		-
7.0	Supplying, Installing, Testing & Commissioning of G.I. Earthing Strips , it shall be run on floor / ceiling / walls, from MCC Panel to all Pumps with necessary accessories as required. Earthing for MCC Panel should be provided by Client.				
a	50mm x 6mm	Rmt.	50		-
b	25mm x 3mm	Rmt.	50		-



8.0	Supplying, Installing, Testing & Commissioning of MS "C" Class Pipes , Heavy grade, Cutting & Fixing the Pipe on Walls / Hanging from ceiling complete. Pipe Fittings such as Reducers, elbows will be Butt Welded Fittings for all size pipes, it should include MS Support such as "L" Angle, as per drawing and all other GI support like Fastener, Thread Rod, U Clamps, U Bolt, Nut, Bolt & Washer, etc., Quoted Rate includes 1 coat of primer and 2 coats of Paint for the Entire System				
a	200mm nominal dia	Rmt.	40		-
b	250mm nominal dia	Rmt.	30		-
9.0	Supplying, Installing, Testing & Commissioning of GI "C" Class Pipes confirming to IS 1239 Pt - I Heavy grade, Cutting & Fixing the Pipe on Walls / Hanging from ceiling complete. Pipe Fittings such as Reducers, elbows will be Butt Welded Fittings for all size pipes, it should include MS Support such as "L" Angle, as per drawing and all other GI support like Fastener, Thread Rod, U Clamps, U Bolt, Nut, Bolt & Washer, etc., Quoted Rate includes 1 coat of primer and 2 coats of Paint for the Entire System				
a	50mm nominal dia	Rmt.	Ro		-
b	80mm nominal dia	Rmt.	25		-
c	100mm nominal dia	Rmt.	1350		-
d	150mm nominal dia	Rmt.	1250		-
10.0	Supplying, Installing, Testing & Commissioning of C.I. Non Return Valves (PN 16) as per IS:5312 wafer type with required flanges, nuts, bolts and gaskets etc. complete.				
a	80 mm nominal dia	Nos.	2		-
b	150 mm nominal dia	Nos.	4		-
11.0	Supplying, Installing, Testing & Commissioning of C.I. Butterfly Valves as per BS 5155 (PN 16) slim seal standard lever operated type with required flanges, nuts, bolts etc.				
a	50mm nominal dia	Nos.	Ro		-



b	80mm nominal dia	Nos.	2		-
c	100mm nominal dia	Nos.	2		-
d	150mm nominal dia	Nos.	4		-
e	200mm nominal dia	Nos.	5		-
f	250 mm nominal dia (Gear Operated Type)	Nos.	1		-
12.00	Supplying, installing and commissioning C. I. flanged "Y" type Strainer with SS mesh, suitable flanges, nuts, bolts, gaskets etc. complete. (suction side) (PN10)				
a)	250mm dia.	Nos.	1		-
13.0	Supplying, Installing, Testing & Commissioning of C.I. Sluice Valves (PN 16) with required flanges, nuts, bolts etc.				
a	80mm nominal dia	Nos.	2		-
b	100mm nominal dia	Nos.	Ro		-
c	150mm nominal dia	Nos.	4		-
14.0	Supplying, Installing, Testing & Commissioning of suitable range Pressure Gauge for pumpsets with 15mm Needle Valve , fittings like unions / colors / reducers etc.	Nos.	2		-
15.0	Supplying, Installing, Testing & Commissioning of Pressure Switch suitable range for pumpsets with 15mm Needle Valve , fittings like unions / colors / reducers etc.	Nos.	6		-
16.0	Supplying, Installing, Testing & Commissioning of Automatic Air Release Valve with 20mm Needle Valve , fittings like unions / colors / reducers etc.				
a	20 mm nominal dia	Nos.	2		-
17.0	Supplying, Installing, Testing & Commissioning of Gun metal chrome finished Needle Valves with fittings of screwed end type.				
a	15mm nominal dia	Nos.	22		-
b	20 mm nominal dia	Nos.	12		-
18.0	Supplying, Installing, Testing & Commissioning of Gun metal chrome finished Needle Valves with fittings of				



	screwed end type.				
a	25mm nominal dia	Nos.	4		-
19.0	Supplying, Installing, Testing & Commissioning of Exhaust Pipe for Diesel Engine, 150 mm dia M.S. Heavy grade Pipe with mineral wool insulation with aluminum sheeting.	Rmt.	50		-
20.0	Supplying, Installing, Testing & Commissioning 100mm & 150mm dia M.S. Heavy Grade Pipe , shall be laid above ground with structural steel supports.	Rmt.	300		-
21.0	Excavation of trenches up to 1.5 mts. in depth, for laying pipes upto 150mm dia. Including forming bottom surface to required level, refilling the trenches with selected excavated earth around the pipe in layers of 150mm thick, watering, consolidating. Quoted price inclusive of disposing off / Carting away the surplus earth out side the site to a dump yard acceptable local bodies or as directed by the site engineer with a lead of 300 mts. etc. complete.	Cum	200		-
22.0	Supplying, installing, testing and commissioning of yard hydrant comprising of the following,				
a)	Single headed hydrant valve as per IS 5290, made of Stainless Steel (SS316) with 63 mm dia instantaneous outlet of 80 mm dia flanged inlet, Blank caps, chain and hand wheels etc. complete.	Nos.	12		-
b)	2 lengths of 15 M long, 63mm dia RRL hose with instantaneous couplings and Hoses shall be stored in side the hose cabinet.	Nos.	12		-
c)	1 no. Stainless Steel (SS316) short branch pipe with nozzle.	Nos.	12		-
d)	M.S. Hose cabinet stand mounted type fabricated out of M.S. sheet of 16 swg. with glass fronted (4mm thick glass with rubber beeding) door and size of the cabinet shall be 600mm x 750 mm x 250 mm Quoted rate shall be includes suitable stand for mounting, all fasteners etc., and cabinet shall be powder coated of approved colour both inside and out side.	Nos.	12		-



TOTAL FOR PART - A					-
B	HYDRANT AND SPRINKLER SYSTEM				
1.0	Supplying, Installing, Testing & Commissioning of 2 way Fire Brigade Inlet connection with built-in 2nos 63 mm dia. SS Non- Return Valves, instantaneous coupling type.	Nos.	1		-
2.0	Supplying, Installing, Testing & Commissioning of 4 way Fire brigade inlet connection with built-in 4 no. 63 mm dia. SS Non- Return Valves, instantaneous coupling type.	Nos.	1		-
3.0	Supplying, Installing, Testing & Commissioning of C.I. Butterfly Valves as per BS 5155 (PN 16) slim seal standard lever operated type with required flanges, nuts, bolts etc.				
a	100mm nominal dia	Nos.	12		-
b	150mm nominal dia	Nos.	12		-
4.0	Supplying, Installing, Testing & Commissioning of GI "C" Class Pipes confirming to IS 1239 Pt - I Heavy grade pipe, laying all size pipes below ground with Butt Welded Fittings like Reducers & elbows, Wrapping & Coating for all Pipes with 4mm thick Polymer Corrosion Resistant Tape with a overlap of 15mm. Quoted Rate includes Excavation up to 1 mts depth in regular soil / soft rock / hard rock and refilling the same with M Sand and compacting it to original condition and removing the extra soil from site.				
a	80mm nominal dia	Rmt.	Ro		
b	100mm nominal dia	Rmt.	Ro		
c	150mm nominal dia	Rmt.	1950		
5.0	supplying,fabricated and installing of M.S fabricating supports pipes and building to building supports	KG	2400		
6.0	scfolding charges for vertical piping support	LOT	1		
TOTAL FOR PART - B					-

	SUMMARY OF FIRE FIGHTING WORKS				
	TOTAL OF PART - B				
	GRAND TOTAL				

The Bidder has to quote the rate in the Item Data available online with this bid. Details to be filled up for price bid are as below:

Sl No	Description	Amount
1	Procurement of Fire Fighting System works at AH&RC	
Sub Total Amount		
GST @ 18%		
Grand Total in INR (Incl. of GST)		
In words:		

Cost related to the works as per Items mentioned in the Compliance sheet for technical proposal.


THE HEAD
CLPC, ACU
Mahalakshmipuram,
Bengaluru - 560 086.