



TENDER NOTIFICATION

The Head, CLPC, Sri Adichunchanagiri Shikshana Trust invites closed tenders from eligible tenderers or bonafide licensed manufacturer (OEM) or their authorized local supplier/ dealer/ distributor in the state of Karnataka for the **Supply and Installation of WTP and Transfer Pumps for underground Sump at BGSMCH Nagarur**. As per section I & II.

1	Name of the work	Supply and Installation of WTP and Transfer Pumps for underground Sump at BGSMCH Nagarur
2	Last Date for Tender Submission	On or before 18.08.2026 before 5.30 PM

Section-1

Instructions to Tenderers

- 1) The Tenderer shall submit the bids (Technical & Financial bids) through the mail id: clethead@bgscet.ac.in on or before the last date of tender submission (for any or all list of items) on professional business letterheads only. The details to be printed on the letter head is as follows.

Tender for **Supply and Installation of WTP and Transfer Pumps for underground Sump at BGSMCH Nagarur**.

Tender Reference number:

Address to "The HEAD, CLPC, Sri Adichunchanagiri Shikshana Trust, BGSCET Campus, Mahalakshmpuram, Bengaluru – 560086"

- i) The tenderer shall submit the original documents to this office on the last day of submission for verification who prefers to submit the tender through Post can dispatch the same through Registered post / Speed post or Couriers as to reach the above address on or before the due date and time specified in the Tender Notice. Tenders received after the due date and time, for what so ever reasons will not be considered and the authority, Head of CLPC will not be liable or responsible for the same.
- 2) **Tender Currency:** Prices shall be quoted in Indian Rupees only.
- 3) **AMC/CMC (IF ANY)** is subject to the Sri Adichunchanagiri shikshana trust's norms.
- 4) **Warranty:** 3 Years.



- 5) **Amendment of tender documents:** At any time prior to the deadline of submission of tenders the trust may, for no reason, whether as its own initiative or otherwise modify the tender documents by amendment. Sri Adichunchanagiri Shikshana Trust reserves all the rights to accept, reject, incorporate changes and re-tender without giving any reasons.
- 6) **Documents Comprising the Tender:** Shall attach Brochure, Certification of the product, Bank/account details, PAN, GSTIN, Good Standing Certificate and 02 years of ITR declaration inside the envelope and the company contact details with email id on the in the below mention format in annexure - 1.
- 7) **Tender Prices:** Prices indicated on the price schedule shall be entered separately i.e. the price of the goods, quoted (ex-works, ex-factory, ex-showroom, ex-warehouse, or off-the-shelf, as applicable), including all duties and sales and the other taxes already paid or payable. Any Indian duties, sales and other taxes which will be payable on the goods if the contract is awarded. Conditional tenders will not be considered. The bidder has to give the quotation in the below enclosed format in annexure – 2.
- 8) **Validity of the Bid:** 90 days from the last date of submission of bid.
- 9) **Corrupt or Fraudulent practices:** Sri Adichunchanagiri Shikshana Trust requires that the tenderers, observe the highest standard of ethics during the procurement and execution of such contracts. In purchase of this policy:
 - a) Will reject a proposal for award if it determines the tenderer recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question;
 - b) Will declare a firm ineligible, either indefinitely or for the stated period of time, to be awarded a university contract if it any time determines that the firm has engaged in corrupt or fraudulent practices in competing for, or in executing, a trust contract.
- 10) **Process to be confidential:** Information relating to the examination, clarification, evaluation, and comparison of tenders and recommendations for the award of contract will not be disclosed to tenderers or any other persons not officially concerned with such process until the award to the successful tenderer has been announced. Any effort by a tenderer to influence the employer's processing of tenders or award decisions may result in rejection of his tender.
- 11) **Clarification of Tenders:** To assist in the examination, evaluation, and comparison of tenders the employer may, at his discretion, ask and tenderer for clarification of his tender, including breakdowns of unit rates. The request for clarification and the response shall be writing or by cable, but no change in the price or substance of the tender shall be sought, offered, or permitted except as required to confirm the correction of arithmetic errors discovered by the employers in the evaluation of the tenders.
- 12) **Delivery:** The successful BIDDER should commence the service as per the tender document/work or purchase order. For any queries or assistance, please write to clethead@bgscet.ac.in or telephone to +91- 8123707324.
- 13) **Penalty Clause:** Non-execution of supply order – for the reasons of failure to supply



partially or completely within the stipulated time or any event of breach of contract. In case at any following stages

- a) For the delayed supply (3 days of grace period) – 5% deduction
- b) Quantity issues – 5 % deduction
- c) Quality issues – 10% deduction.
- d)

Section-2

Bill of Quantities (BOQ) – WTP Pumps & Equipment's					
S N	DESCRIPTION	UNIT	QTY	RATE (IN RS.)	AMOUNT (IN RS.)
A	WTP PUMPS & EQUIPMENTS				
1	Supply, installation, testing and commissioning of SS 304 Vertical / Horizontal centrifugal pump. Each pump shall have TEFC 2900 RPM three phase electric motor. The pump shall have cast iron head, base plate SS 304 Shaft/ Impeller/ Inter-mediate chamber. Pump shall be provided with mechanical seal. Cost shall includes level controller to start / stop the pump including wiring, cabling from the pump to panel & other accessories as required to auto/manual operate the system.				
1.1	Nos. of Pumps : 3 (2 W+ 1 SB)	Set	1		
	Flow rate :7 lps				
	Head : 30 Mts				
	Isolation Valve : 80mm (PN10)- 6 Nos				
	Cast Iron NRV - 80 mm (PN10) - 3 Nos.				
	Pressure gauge at delivery header: 1 No.				
	Location : Plumbing Plantroom (Basement)				
	Purpose : Filter Feed Pump.				
2	Supply, installation, testing and commissioning of FRP composite filter with media, with 80 mm diameter CPVC sch 80 frontal piping complete with multiport valave arrangement. Filter shall be suitable for working pressure of 2.5 - 3.0 bars and shall include standard fittings like manhole cover, legs, pressure gauges, sampling cock, rinse drain, niddle valve and all				



	accessories for complete as required.				
2.1	Multi Grade Filter	Set	2		
	Flow rate : 7 lps				
	Filtration Velocity: 18000 lts/hrs/ sqm.				
	Filter Diameter :1400 mm Approx.				
	Other Accessories on the Filter Pressure Gauge, Niddle Valve and all accessories for complete working of the Filter.				
	Location : Plumbing Plantroom (Basement).				
2.2	Activated Carbon Filter	Set	2		
	Flow rate : 7 lps				
	Filtration Velocity: 15000 lts/hrs/ sqm.				
	Filter Diameter : 1500 mm Approx.				
	Other Accessories on the Filter Pressure Gauge, Niddle Valve and all accessories for complete working of the Filter.				
3	Providing, fixing, testing & commissioning of Chlorine dozing pump with 100 lits. HDPE/ FRP solution tank, injection fitting assembly, suction and delivery hose upto the point of injection, capacity 2.5 ml/hr to 7.5 l/h at 3 kg/sq.cm injection pressure, complete in all respects for treated water tank.Dosing pump shall be with powerful variable-speed stepper motor with internal stoke speed control and the turndown ratio of pump shall not below 1:3000. Accuracy of repeatability shall be +/- 1%.Pump shall be compatible to handle the liquid temperature range between -10 °C to 45°C.(Make Grundfos)	Set	2		
	Location : Plumbing Plantroom (Basement).				
6	Providing, fixing, testing & commissioning of Hypo dozing (SHMP) pump with 100 lits.HDPE/ FRP solution tank, injection fitting assembly, suction and delivery hose upto the point of injection, capacity 0-6 lph at 3 kg/sq.cm injection pressure, complete in all respects for treated water tank. Operation of pumps shall be tanker water inlet flow switch.	Set	2		



7	Providing and Fixing electrically operated water flow switches (paddle type) complete with tap off socket arrangement as required, with potential free contact with 2 Nos. NONC.	Set	2		
8	Fixed Speed Hydropneumatic System. Supply, Installation, Testing And Commissioning of Compact Self Contained Skid Mounted Hydropneumatic System as follows: a. In-Line, Multistage, centrifugal pumps with SS-304 casing and impeller and SS-304 shaft, CI base & head TEFC motor (with mechanical seal). (Vendor to submit performance curves and technical catalogue of the proposed model for review & information). The pump shall be selected for performance at best efficiency point. However, the pump selection shall be suitable for performance with set point @ + 20% of the rated head. b. External Pump mounted or wall mounted microprocessor PID controller with pressure sensor transmitter minimum two lined LCD display, diodes to indicate pump ready, pump running and fault and capable to communicate with other controllers following MODBUS-RTU or BACNET Class-2 protocol through RS485 port. System should be capable to compensate for frictional losses at lower flows. All alarms should be displayed in the controller. System should be equipped with dry running protection. Quantity : 1 Nos. c. Complete (Skid mounted wall mounted/floor mounted) electrical control panel comprising of all accessories such as PLCs, pressure switches, pressure transducers, control wiring and any other necessary imports etc. (list to be provided by the vendor). d. Precharged diaphragm pressure vessel with foodgrade membrane, charging connection, connected to outlet header with necessary flanges, gaskets, isolating valves, nuts/bolts etc complete. e. Set of accessories such as pressure switches, pressure transducers, inter connecting power and control cabling etc. complete.				



	f. Accessories like NRVs, isolating valves, SS 304 heavy class suction and delivery header, pressure gauge, MS base frame (Synthetic enamel painted over a coat of primer).				
	g. Pressure Vessel (Capacity to be mentioned by Vendor)				
8.1	Nos. of Pumps : 3 (2 Working + 1 Stand By)	Set	1		
	Flow rate : 9 lps				
	Head : 90Mts				
	RPM : 2900				
	Location : Plumbing Plant room (Basement)				
	Purpose : Domestic water transfer pump to OHT				
9	Supply, installation, testing and commissioning of continuous duty submersible centrifugal non-clogging drainage pumps complete with 3 phase motor with all necessary protection and mechanical seal etc. complete with all ancillaries including heavy duty GI piping, float type level controllers, starter with Automatic float type level controller, provision of high level alarm, sequence timer, both pumps may run simultaneously at pre determined level along with one panel complete.				
9.1	Vendor to submit proposed pump model with duty curve.	Set	1		
	Nos. of Pumps : 2 (1 Working + 1 Stand By)				
	Flow rate : 180 LPM				
	Head : 12 Mts				
	Solid Handling : 10-12 MM				
	Purpose : Drainage				
	MOC : CI				
	Butterfly Isolation Valve : 65 mm (PN10)- 2 Nos				
	Cast Iron NRV : 65 mm (PN10) - 2 Nos.				
	Location : Plumbing Plant room (Basement)				
9.2	Vendor to submit proposed pump model with duty curve.	Set	1		



Nos. of Pumps : 2 (1 Working + 1 Stand By)				
Flow rate : 180 LPM				
Head : 12 Mts				
Solid Handling : 38 MM				
Purpose : Sewerage				
MOC : CI				
Butterfly Isolation Valve : 65 mm (PN10)- 2 Nos				
Cast Iron NRV : 65 mm (PN10) - 2 Nos.				
Location : Plumbing Plant room (Basement)				
TOTAL CARRIED TO SUMMARY (A)				-


The Bidder has to quote the rate in the Item Data available online with this bid. Details to be filled up for price bid are as below:

The price shall be inclusive of all taxes (inclusive of GST) under the relevant Laws of India.

SL. No	Particular	Amount In Rs. (Inclusive of All the taxes)
1	Total Amount for Supply and Installation of WTP and Transfer Pumps for underground Sump at BGSMCH Nagarur	
	Grand Total	

in words –Rs.


THE HEAD
CLPC, ACU
Mahalakshmiipuram,
Bengaluru - 560 086.



Handwritten signature



PARTICULARS OF THE BIDDER

Sr. No	Description	Details (to be filled by the responder to the Bid)
1	Name of the company	
2	Official address	
3	Phone No. And Fax No.	
4	Corporate Headquarters Address	
5	Phone No. And Fax No.	
6	Web Site Address	
7	Details of Company's Registration (Please enclose copy of the company registration document)	
8	Name of Registration Authority	
9	Registration Number and Year of Registration	
10	ISO certifications and its validity	
11	GST registration No.	
12	Permanent Account Number (PAN)	
13	Company's Revenue for last 3 years (Year wise)	
14	Company's net worth for the last year	
15	Bank Details (Name, Account no, IFSC, MICR)	